



Vda Gabriel Marí Montaña “PRACTIC” with CIF A46036562, declares that the tested chimney system at BSRIA Laboratory on 18th of September 2020 it is a chimney system manufactured in production state and its production process began in 2015.


We declare that this new product, identified as Elite DP or double wall T600, has been re-tested by the BSRIA laboratory, obtaining an improvement in the designation of distance to combustible materials.

4.7 PRODUCT DESIGNATION

The designation achieved was as follows;

Standard	Temperature level	Pressure level	Condensate resistance	Corrosion resistance	Material specification	Sootfire resistance
EN 1856-1	T600	N1	D	V2	L50040	G(50)

Laboratory report





Classification obtained

4.2 CLASSIFICATION FOR TEST

Testing will be carried out against the classifications below as stated by manufacturer.

Temperature class	T600
Pressure class	N1
Condensate class	D
Corrosion resistance class	V2
Flue liner material specification	L50040
Sootfire resistance class	G
Distance to combustibles	50

Test Results

4 TEST RESULTS

Table 3 Findings of examination to relevant clauses from BS EN 1856-1:2009

BS EN 1856-1 clause	Description of test	Complies?	
		Yes	No
4	Manufacturer's declaration for type test	Yes	4.1
-	Classification	Yes	4.2
6.3	Resistance to fire (internal to external)	Yes	4.3
6.5	Gas tightness	Yes	4.4
6.6.1	Safety in use, heat stress test	Yes	4.5
6.7	Durability of flue liner against corrosion	Yes	4.6
9	Product designation	Yes	4.7

Signed by :

Amparo de Pablo

Charge:

Resp. Technical Office



Valencia, España.

27/10/2020